

HENGKO TEMPERATURE AND HUMIDITY PROBE DATA SHEET

Model	Humidity Accuracy(%RH)	Temperature (°C)	Voltage Supply(V)	Interface	Relative Humidity Range(RH)	Temperature Range
RHT-H30	± 2.0 @ 10-90% RH	± 0.2 @ 0-65 °C	2.15 to 5.5	I ² C	0-100%	Minus 40 to ± 125 °C
RHT-H31	± 2.0 @ 0-100% RH	± 0.2 @ 0-90 °C	2.15 to 5.5	I ² C	0-100%	Minus 40 to ± 125 °C
RHT-H35	± 1.5 @ 0-80% RH	± 0.1 @ 20-60 °C	2.15 to 5.5	I ² C	0-100%	Minus 40 to ± 125 °C
RHT-H20	± 3.0 @ 20-80% RH	± 0.3 @ 5-60 °C	2.1 to 3.6	I ² C	0-100%	Minus 40 to ± 125 °C
RHT-H21	± 2.0 @ 20-80% RH	± 0.3 @ 5-60 °C	2.1 to 3.6	I ² C	0-100%	Minus 40 to ± 125 °C
RHT-H25	± 1.8 @ 10-90% RH	± 0.2 @ 5-60 °C	2.1 to 3.6	I ² C	0-100%	Minus 40 to ± 125 °C